



Sika Deutschland GmbH
Report No. SI 2305-1426

Cleanroom[®] Suitable Materials

SR-304 W + 5% GK
(structured)

Riboflavin Test: good

FLOORING & COATING

Single product Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 2305-1426.

The examination of cleanability of Sikafloor-304 W + 5 % Glaskugeln 90-150 µm (color: telegray) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
Sikafloor-304 W + 5 % Glaskugeln 90-150 µm (structured)	good

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

SI 1611-861
Report No. first document
SI 2305-1426
Report No. current document

Stuttgart, March 16, 2017
Place, date of first document issued
Stuttgart, September 7, 2023
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA