



Cleanroom® Suitable Materials

StoCretec GmbH
Report No. ST 2601-1714
Cleanroom (atmospheric)

StoFloor Cleanroom System 2
Biological Resistance:
none

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 2601-1714.

The biological resistance of the StoFloor CR System 2 (StoPox GH 205; StoPox KU 601) (RAL 7035) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	0	excellent
Procedure C (resistance to bacteria)	3	none
Overall result	none	

The classification is based on a worst-case consideration of the Procedures A and C.

ST 1902-1095
Report No. first document
ST 2601-1714
Report No. current document

Stuttgart, November 6, 2019
Place, date of first document issued
Stuttgart, May 6, 2026
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

DUPLICATE