



# Cleanroom<sup>®</sup> Suitable Materials

StoCretec GmbH  
Report No. ST 2601-1714  
Cleanroom (atmospheric)

StoFloor Cleanroom System 2  
H<sub>2</sub>O<sub>2</sub> Absorption/Desorption:  
non-absorptive

## FLOORING & COATING

### Single product Hydrogen Peroxide Absorption/Desorption

### Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH  
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 2601-1714.

The hydrogen peroxide absorption/desorption of StoFloor CR System 2 (StoPox GH 205; StoPox KU 601) (RAL 7035) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
4.77	0.83	non-absorptive

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

DUPLICATE

ST 1902-1095  
Report No. first document

ST 2601-1714  
Report No. current document

Stuttgart, February 28, 2019  
Place, date of first document issued

Stuttgart, May 6, 2026  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification