



Cleanroom[®] Suitable Materials

StoCretec GmbH
Report No. ST 2601-1714
Cleanroom (atmospheric)

StoFloor Cleanroom System 14
H₂O₂ Absorption/Desorption:
fast

FLOORING & COATING

Single product Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 2601-1714.

The hydrogen peroxide absorption/desorption of StoFloor CR System 14 (StoPox GH 205; StoPox WL 110; StoPox KU 614) (RAL 7035) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
13.21	0.58	fast

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

DUPLICATE

ST 2601-1714
Report No. first document
--
Report No. current document

Stuttgart, May 6, 2026
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification