



Cleanroom® Suitable Materials

StoCretec GmbH
Report No. ST 2601-1714
Cleanroom (atmospheric)

StoFloor Cleanroom System 2
(smooth)
Riboflavin Test: excellent

FLOORING & COATING

Single product
Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

StoCretec GmbH
Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 2601-1714.

The examination of cleanability of StoFloor CR System 2 (StoPox GH 205; StoPox KU 601) (RAL 7035) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
StoFloor CR System 2 (StoPox GH 205; StoPox KU 601) (smooth)	0; excellent

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

DUPLICATE

ST 1902-1095
Report No. first document
ST 2601-1714
Report No. current document

Stuttgart, February 28, 2019
Place, date of first document issued
Stuttgart, May 6, 2026
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification